

IMPORTANT NOTES:

- Council's stormwater detention requirements apply to all dwellings.
- Each dwelling must detain a minimum of 2000 litres (2 cubic metres) of stormwater from the roof area.
- A minimum of 60% of the roof area of each dwelling must be directed through the detention system, with a maximum outflow rate of 3 litres per second.
- In developments with large areas of impervious surface (such as shared driveways and parking areas), additional detention for those areas may also be required.

REVISIONS AND ISSUES		DRAWING SHEET DETAILS			DESIGN VERIFICATION					
REV ISSUE/DESCRIPTION	DATE APPROVED	DRAWING SHEET DETAILS			DESIGN TITLE	NAME	SIGNATURE DATE	City of Campbelltown MINIMUM RETENTION AND DETENTION DETAILS		
A FOR APPROVAL	15 APRIL 2013	ORIGINAL A1			INFRASTRUCTURE PLANNING ENGINEER	SS	15 APRIL 2013			
B AS REQUESTED BY PLANNING DEPARTMENT	OCT 2015				INFRASTRUCTURE PLANNING ENGINEER	SS	SEP 2017			
C CHANGES MADE FOLLOWING ADOPTION OF DEV PLAN	SEP 2017	SCALES NOT TO SCALE								
		COORDINATE SYSTEM	×1							
		CAD FILE NAME STANDARDS_FINAL_RECOVER								
		DRAWN BY SS						PLAN No. SD 12	SHEET	REV.